Energy Consumption and Greenhouse Gas Emissions Reporting - for 2018

Confirm consecutive 12-mth period (mth-yr to mth-yr)	Jan/2018 - Dec/2018
Sector	Acute/Chronic Hospital
Agency Sub-sector	Public Hospital
Organization Name	Hotel-Dieu Grace Healthcare

Operation Name	Operation Type	Address	City	Postal Code	Total Floor Area	Unit	Avg hrs/wk	Electricity Quantity	Electricity Unit	Natural Gas Quantity	Natural Gas Unit	Fuel Oil 1 & 2 Quantity	Fuel Oil 1 & 2 Unit	Fuel Oil 4 & 6 Quantity	Fuel Oil 4 & 6 Unit	Propane Quantity	Propane Unit	Coal Quantity	Coal Unit	Wood Quantity	Wood Unit	District Heating Quantity	District Heating Unit	Renewable?	If Yes, enter Emission Factor	District Cooling Quantity	District Cooling Unit	Renewable?	If Yes, enter Emission Factor	GHG Emissions (Kg)	Energy Intensity (ekWh/sqft)	Building / Operation Identifier	Comments
Stephenson Building	*Administrative offices and related facilities*	*2160 Yonge Street*	*Toronto*	*M4A 2G5*	*135,034.00*	*Square feet*	*70*	*2,181,065.00000*	*kWh*	*125,300.00000*	*Cubic meter*	*110,000.00000*	*Litre*	*23,000.00235*	*Litre*		*Litre*		*Metric Tonne*		*Metric Tonne*	*26.73000*	*Giga Joule*	*No*	*0.00000*	*20.50600*	*KL Chilled Water*	*No*	*0.00000*				*max. 255 characters*
Hotel Dieu Grace Hospital	Facilities used for hospital purposes	1691 Huron Church F	Windsor	N9C 3E6	1.00	Square feet	168	1,776.24410	kWh	9,985.58000	Cubic Meter																			52.48446	1,776.24410		
Hotel Dieu Grace Hospital	Facilities used for hospital purposes	3902 Connaught Ave	Windsor	N9C 3E6	8,930.00	Square feet	168	125,809.71310	kWh																					22,596.43256	25.97248		
Hotel Dieu Grace Hospital	Facilities used for hospital purposes	3901 Connaught Ave	Windsor	N9C 3E6	24,910.00	Square feet	168	287,463.66000	kWh	17,257.27900	Cubic Meter																			41,121.05385	18.90286		
Hotel Dieu Grace Hospital	Facilities used for hospital purposes	3903 Connaught Ave	Windsor	N9C 3E6	10,212.00	Square feet	168	132,420.20700	kWh	47,435.92700	Cubic Meter																			93,596.39663	62.33438		
Hotel Dieu Grace Hospital	Facilities used for hospital purposes	3896 Connaught Ave	Windsor	N9C 2C1	29,186.00	Square feet	168	224,516.76000	kWh	14,614.07100	Cubic Meter																			34,263.77844	13.01418		
Hotel Dieu Grace Hospital	Facilities used for hospital purposes	3520 Douarill Ave	Windsor	N9E 1T2	2,500.00	Square feet	168	26,603.26300	kWh	8,292.36200	Cubic Meter																			16,463.83671	45.89305		
Hotel Dieu Grace Hospital	Facilities used for hospital purposes	1106 Ouilette Avenue	Windsor	N9C 2C2	10,600.00	Square feet	168	146,855.29000	kWh	8,486.02000	Cubic Meter																			20,383.17864	22.36253		
Windsor Regional Hospital Taylo	Facilities used for hospital purposes	1453 Prince Rd	Windsor	N9C 3Z4	701,930.00	Square feet	168	9,446,521.95000	kWh	1,755,928.93900	Cubic Meter																			3,598,932.53055	40.04408		