Energy Consumption and Greenhouse Gas Emissions Reporting - for 2020

Confirm consecutive 12-mth period (mth-yr to mth-yr)	Jan/2020 - Dec/2020
Sector	Acute/Chronic Hospital
Agency Sub-sector	Public Hospital
Organization Name	Hotel-Dieu Grace Healthcare

Operation Name	Operation Type	Address	City	Postal Code	Total Floor Area	Unit	Avg hrs/wk	Electricity Quantity	Electricity Unit	Natural Gas Quantity	Natural Gas Unit	Fuel Oil 1 & 2 Quantity	Fuel Oil 1 & 2 Unit	Fuel Oil 4 & 6 Quantity	Fuel Oil 4 & 6 Unit	Propane Quantity	Propane Unit	Coal Quantity	Coal Unit	Wood Quantity	Wood Unit	District Heating Quantity	District Heating Unit	Renewable?	If Yes, enter Emission Factor	District Cooling Quantity	District Cooling Unit	Renewable?	If Yes, enter Emission Factor	GHG Emissions (Kg)	Energy Intensity (ekWh/sqft)	Building / Operation Identifier	Comments
Stephenson Building	*Administrative offices and related facilities*	*2160 Yonge Street*	*Toronto*	*M4A 2G5*	*135,034.00*	*Square feet*	*70*	*2,181,065.00000*	*kWh*	*125,300.00000*	*Cubic meter*	*110,000.00000*	*Litre*	*21,000.00235*	*Litre*		*Litre*		*Metric Tonne*		*Metric Tonne*	*26.73000*	*Giga Joule*	*No*	*0.00000*	*20.50600*	*KL Chilled Water*	*No*	*0.00000*				*max. 255 characters*
Hotel Dieu Grace Hospital	Facilities used for hospital purposes	3896 Connaught Ave	Windsor	N9C 2C1	29,186.00	Square feet	168	228,801.89000	kWh	13,871.36900	Cubic Meter																			32,048.13526	12.89055		
Hotel Dieu Grace Hospital	Facilities used for hospital purposes	3520 Dougall Ave	Windsor	N9E 1T2	2,500.00	Square feet	168	19,750.41970	kWh	4,242.59900	Cubic Meter																			8,523.78090	25.93593		
Hotel Dieu Grace Hospital	Facilities used for hospital purposes	1691 Huron Church R	Windsor	N9C 2E6	1.00	Square feet	168	1,402.34150	kWh																					35.68679	1,402.34150		
Hotel Dieu Grace Hospital	Facilities used for hospital purposes	3902 Connaught Ave	Windsor	N9C 3E6	8,930.00	Square feet	168	104,701.83250	kWh	9,617.02400	Cubic Meter																			20,846.65747	23.17015		
Hotel Dieu Grace Hospital	Facilities used for hospital purposes	1106 Ouellette Avenue	Windsor	N9C 2C2	10,600.00	Square feet	168	153,214.75500	kWh	7,356.45500	Cubic Meter																			17,807.32153	21.82995		
Hotel Dieu Grace Hospital	Facilities used for hospital purposes	3903 Connaught Ave	Windsor	N9C 3E6	10,212.00	Square feet	168	134,041.29290	kWh	23,075.35700	Cubic Meter																			47,037.97580	37.14072		
Hotel Dieu Grace Hospital	Facilities used for hospital purposes	3901 Connaught Ave	Windsor	N9C 3E6	24,910.00	Square feet	168	257,547.81000	kWh	39,638.78300	Cubic Meter																			81,496.23006	27.25090		
Windsor Regional Hospital Tavis	Facilities used for hospital purposes	1453 Prince Rd	Windsor	N9C 3Z4	701,930.00	Square feet	168	9,503,186.44000	kWh	1,668,832.81700	Cubic Meter																			3,396,977.47083	38.80611		